टेलीफोन: 0522- 2465704 फैक्स : 91-0522 -2465704 E-mail: dbscb2rdso@gmail.com



भारत सरकार – रेल मंत्रालय अनुसंधान अभिकल्प और मानक संगठन लखनऊ - 226011 Government of India-Ministry of Railways Research Designs & Standards Organisation Lucknow- 226011

Dated: 16.12.2014

No. CBS/Code/A&C

Principal Chief Engineer:

Central Railway, Mumbai CST-400 001.

Eastern Railway, Fairlie Place, Kolkata-700 001. 2.

East Central Railway, Hazipur-844 101. 3.

East-Coast Railway, Bhubaneshwar-751 016. 4.

Northern Railway, Baroda House, New Delhi- 110 001. 5.

North-Central Railway, Allahabad-211 001. 6.

North Eastern Railway, Gorakhpur-273 001. 7.

North-Western Railway, Jaipur-302 001.

Northeast Frontier Railway, Maligaon, Guwahati-781 011. 9.

Southern Railway, Park Town, Chennai-600 003. 10.

South Central Railway, Rail Nilayam, Secunderabad-500 371. 11.

South East Central Railway, Bilaspur-495 004 12.

South Eastern Railway, Garden Reach, Kolkata-700 043 13.

South-West Railway, Hubli-580 023. 14.

Western Railway, Mumbai-400 020. 15.

West-Central Railway, Jabalpur-482 001. 16.

Sub: Addendum & Corrigendum slip No. 1 to IRS Concrete Bridge Code,

Reprint 2014 (incorporating A&C 1 to 13).
Railway Board's letter No. 2013/CE-III/BR/RDSO/Misc. Ref.: 16.12.2014.

As approved by Railway Board vide letter under reference above, Addendum & Corrigendum Slip No. 1 to IRS Code of Practice for Plain, Reinforced and Prestressed Concrete for General Bridge Construction (Concrete Bridge Code) Reprint 2014 (incorporating A&C 1 to 13) regarding revision to clause 10.2.1(a) is enclosed for information and necessary action please.

Encl: As above.

(Pradip Kumar) Director/B&S/CB-II For Director General

GOVERNMENT OF INDIA MINISTRY OF RAILWAYS (Railway Board)

INDIAN RAILWAY STANDARD

CODE OF PRACTICE FOR PLAIN, REINFORCED AND PRESTRESSED CONCRETE FOR GENERAL BRIDGE CONSTRUCTION (CONCRETE BRIDGE CODE)

ADOPTED - 1936 FIRST REVISION - 1962 SECOND REVISION - 1997 REPRINT-2014 (Incorporating A&C 1 to 13)

ADDENDUM & CORRIGENDUM SLIP NO. 1 DATED 16.12.2014

(1) Clause 10.2.1 (a):
Replace Table 10 as below:

TABLE 10: DESIGN CRACK WIDTHS [Cl. 10.2.1 (a)]

Exposure Conditions	Design crack width in mm
Moderate	0.25
Severe	0.20
Extreme	0.10

Note – Exposure conditions are as defined in 5.4.1.

BY ORDER:

LUCKNOW Dated: 16.12.2014

(H.L.Suthar)

Executive Director/Structures
B&S Directorate

R.D.S.O.